

Joy Preparatory Academy-Dexter Campus Completed Emergency Drills Report Form-2015-2016

Fire Prevention Act 207 Section 29.19 (as amended effective July 1, 2014) outlines the requirements for schools operating any of grades kindergarten to 12. The specific sections for Fire Drills, Tornado Drills and Lock Downs are listed below.

In addition, the following pertains to ALL DRILLS in Section 19 of the Act:

Sec. 19 (6) A school that operates any of grades kindergarten to 12 shall conduct at least one (1) of the drills required by this section during a LUNCH or RECESS period, or at another time when a significant number of the students are gathered but not in the classroom.

Fire Drills

Sec. 19 (3) A minimum of five (5) fire drills is required for each school year for a school that operates any of grades kindergarten to 12. Three (3) of the fire drills shall be held by December 1 of the school year, and two (2) shall be held during the remaining part of the school year, with a reasonable spacing interval between each drill.

Fire Drills

Date	Time Drill(s) Conducted	# of Participants	Evacuation Time	Comments
10-2-15	9:33a.m.	131	56sec	Doors in all classrooms were closed. Very smooth, quick evacuation!!
10-27-15	11:30a.m.	135	54sec	All doors and windows were closed. Very quick evacuation.
11-11-15	2:20p.m.	128	51sec	All doors and windows were closed.

Lock Down Drills

Date	Time Drill(s) Conducted	Drill Conducted (Initial/Identify)	By:	Comments
11-17-15	9:30a-10:45a	Fran Gardulescu		Simulation of an unknown, belligerent person in the building.

Tornado Drills

Date	Time Drill(s) Conducted	# of Participants	Response Time	Comments
12-1-15	1:30p.m.	132	6seconds	All protocols were followed. Response time was quick.

Fran Gardulescu January 13, 2016
Administrator's Signature/Date

FTDR-001