

Joy Preparatory Academy-Dexter Campus Completed Emergency Drills Report Form-2014-2015

Fire Prevention Act 207 Section 29.19 (as amended effective July 1, 2014) outlines the requirements for schools operating any of grades kindergarten to 12. The specific sections for Fire Drills, Tornado Drills and Lock Downs are listed below.

In addition, the following pertains to ALL DRILLS in Section 19 of the Act:

Sec. 19 (6) A school that operates any of grades kindergarten to 12 shall conduct at least one (1) of the drills required by this section during a LUNCH or RECESS period, or at another time when a significant number of the students are gathered but not in the classroom.

Fire Drills

Sec. 19 (3) A minimum of five (5) fire drills is required for each school year for a school that operates any of grades kindergarten to 12. Three (3) of the fire drills shall be held by December 1 of the school year, and two (2) shall be held during the remaining part of the school year, with a reasonable spacing interval between each drill.

Fire Drills

Date	Time Drill(s) Conducted	# of Participants	Evacuation Time	Comments
9-23-14	10:50a.m.	171	2min5sec	Doors in all classrooms must be closed.
9-29-14	12:15p.m.	174	1min54sec	Classroom doors were all closed. Doors to lunchrooms must be monitored by custodian and closed.
10-16-14	2:25p.m.	172	1min44sec	All doors and windows were closed.

Lock Down Drills

Date	Time Drill(s) Conducted	Drill Conducted (Initial/Identify)	By:	Comments
11-18-14	9:50-10:55	Fran Gardulescu		Simulation: The house down the street was being raided.

Tornado Drills

Date	Time Drill(s) Conducted	# of Participants	Response Time	Comments
12-3-14	2:45	158	12 seconds	All classrooms were evacuated and students were in position in halls within 18 seconds. Total drill was 10 minutes.

Fran Gardulescu December 19, 2014
Administrator's Signature/Date

FTDR-001