

Joy Preparatory Academy-Oakman Campus Completed Emergency Drills Report Form-2015-2016

Fire Prevention Act 207 Section 29.19 (as amended effective July 1, 2014) outlines the requirements for schools operating any of grades kindergarten to 12. The specific sections for Fire Drills, Tornado Drills and Lock Downs are listed below.

In addition, the following pertains to ALL DRILLS in Section 19 of the Act:

Sec. 19 (6) A school that operates any of grades kindergarten to 12 shall conduct at least one (1) of the drills required by this section during a LUNCH or RECESS period, or at another time when a significant number of the students are gathered but not in the classroom.

Fire Drills

Sec. 19 (3) A minimum of five (5) fire drills is required for each school year for a school that operates any of grades kindergarten to 12. Three (3) of the fire drills shall be held by December 1 of the school year, and two (2) shall be held during the remaining part of the school year, with a reasonable spacing interval between each drill.

Fire Drills

Date	Time Drill(s) Conducted	# of Participants	Evacuation Time	Comments
9-16-15	11:20a.m.	129	1min7sec	All doors in all classrooms and offices were closed.
9-28-15	2:10p.m.	125	1min20sec	Classroom and office doors were all closed.
10-12-15	1:30p.m.	130	1 min5sec	All windows and doors were closed.
4-20-16	10:30a.m.	127	1 min2sec	All windows and doors were closed.
5-2-16	3:00p.m.	128	1 min4sec	All windows and doors were closed.
5-23-16	10:00a.m.	127	1 min	

Lock Down Drills

Date	Time Drill(s) Conducted	Drill Conducted (Initial/Identify)	By:	Comments
11-6-15	10:00a-11:00a	Fran Gardulescu		Simulation of an unknown, belligerent person who entered the building and refused to leave.
2-18-16	1:30-2:30	Fran Gardulescu		Simulation of gun shots in the neighborhood.

Tornado Drills

Date	Time Drill(s) Conducted	# of Participants	Response Time	Comments
1-11-16	1:00p.m.	125	7 seconds	All protocols were followed. Response time was smooth and rapid.
3-8-16	9:30a.m.	136	6 seconds	All protocols were followed. Response time was smooth and rapid.

Fran Gardulescu June 14, 2016
Administrator's Signature/Date